



SmartBar™ & SmartModule™

User Manual

Version 1.67



Copyright © 2009. Electronic Theatre Controls, Inc.
All Rights reserved.
Product information and specifications subject to change.
Part Number: **7521M1200-1.67** Rev A
Released: 2009-04

ETC, SmartBar, and SmartModule are either registered trademarks or trademarks of Electronic Theatre Controls, Inc. in the United States and other countries. All other trademarks, both marked and not marked, are the property of their respective owners.

ETC intends this document, whether printed or electronic, to be provided in its entirety.

Table of Contents

	Introduction	1
	SmartBar™ & SmartModule™ Models & Features	1
	Using this Manual	2
	Help from ETC Technical Services	3
Section 1:	Unpacking & Setup	4
	Unpacking & Checking	4
	Positioning	4
	Connections	4
	Power Input Connections	4
	Power Output Connections	5
	Convenience Outlet (SmartBars Only)	5
	DMX Data Signal Connections	5
	Safety	5
Section 2:	Control Panel Layout	6
Section 3:	Function Overview	8
	Maximum and Minimum Levels	8
	Response Speed	8
	Non-dim Operation	8
	Local Control	8
	Dimmer Curves	8
	Backup Settings	8
Section 4:	Information Displays & Manual Control	9
	Check Dimmer Information	9
	Check Set Dimmer Main Power Voltage & Frequency	9
	Check Dimmer Software Version	9
	Manually Control a Dimmer Level	10
	Operate the Chaser	10
Section 5:	Programming	11
	Flow Diagram	11
	General Programming Advice	11
	Passwords	11
	Navigation Through the Menus	11
	Channel Characteristics	11
	Front Panel Controls	12
	General Controls	12
	Change the Dimmer Characteristic Setup Scheme	12
	DMX Programming	13
	Set the DMX Addressing Scheme	13

	Set the DMX Addresses	13
	Set the DMX Backup Condition	14
	Set the DMX Backup Preset.	14
	Set the DMX Minimum Reset	15
	Maximum & Minimum levels	16
	Set Max. & Min. Levels.	16
	Response time	16
	Set Dimmer Response Times.	16
	Dimmer Curves	17
	Set a Dimmer Curve	18
	Start Mode.	18
	Set Start Mode	19
	Passwords.	19
	Setup Passwords	19
	Sleep mode.	20
	Set the dimmer rack to Sleep mode	20
	Fault reporting	21
	Check Error Messages & Reset the Log	21
	Restore Factory Defaults	21
	Reset to Factory Default Settings.	21
Section 6:	Faults & Troubleshooting	23
	Reported Faults.	23
	Over Temperature	23
	Over Voltage.	23
	No Load (Control Present But no Output) [SmartModule Only] 23	
	First Line Troubleshooting.	23
	LCD Display Blank	23
	No Output from One Channel.	23
	Breaker Trips Continuously	23
	Dimmer Output is Stuck On Full	23
Appendix A:	Specifications	25
	SmartBar/SmartModule Control Features.	25
	SmartBar Specifications	25
	General.	25
	Physical	26
	26
	Mechanical	26
	Electrical	26
	SmartModule Specifications	27
	General.	27
	Physical	27
	Mechanical	27
	Electrical.	27
Appendix B:	Menu Layout	29


Introduction

SmartBar™ & SmartModule™ Models & Features



The SmartBar and SmartModule products differ in physical likeness but function very similarly and share the same user interface style. Both are fully digital triac dimmers with fuse or circuit breaker overcurrent protection per circuit.

The control panel includes a backlit menu-driven LCD to set and review operational parameters, performance and status information. SmartBar/SmartModule units include many advanced features including remote programming, and software updates via the DMX connector.

This manual describes the operation and programming of the SmartBar and SmartModule dimming products. The models covered in this manual include:



SmartBar Dimmers			
Description	Model #	Amperage/Feed	Load Protection
SmartBar, 4x6A, Edison	SB4-6-A	20A 1phase, 12' 12/3, SO cable	Fuse
SmartBar, 4x6A, Stage Pin	SB4-6-B	20A 1phase, 12' 12/3, SO cable	Fuse
SmartBar, 4x 6A, GTL	SB4-6-C	20A 1phase, 12' 12/3, SO cable	Fuse
SmartBar, 2x10A, Edison w/circuit breakers	SB2-10M-A	20A 1phase, 12' 12/3, SO cable	Breakers
SmartBar, 2x10A, Stage Pin w/circuit breakers	SB2-10M-B	20A 1phase, 12' 12/3, SO cable	Breakers
SmartBar, 2x10A, GTL w/circuit breakers	SB2-10M-C	20A 1phase, 12' 12/3, SO cable	Breakers
SmartBar, 6x10A, Edison w/circuit breakers	SB6-10M-A	20A 3phase, 12' 12/5, SO cable	Breakers
SmartBar, 6x10A, Stage Pin w/circuit breakers	SB6-10M-B	20A 3phase, 12' 12/5, SO cable	Breakers
SmartBar, 6x10A, GTL w/circuit breakers	SB6-10M-C	20A 3phase, 12' 12/5, SO cable	Breakers



SmartModule Dimmers			
Description	Model #	Amperage/Feed	Load Protection
SmartModule, 4x6A, Edison	SB4-6-A	20A 1phase, 12' 12/3, SO cable	Fuse
SmartModule, 4x6A, Stage Pin	SB4-6-B	20A 1phase, 12' 12/3, SO cable	Fuse
SmartModule, 6x10A, Edison w/circuit breakers and GTL input	SM6-10-A	20A, 3phase, Flange mount, GTL	Breakers
SmartModule, 6x10A, Stage Pin w/circuit breakers and GTL input	SM6-10-B	20A, 3phase, Flange mount, GTL	Breakers
SmartModule, 6x10A, GTL w/circuit breakers and GTL input	SM6-10-C	20A, 3phase, Flange mount, GTL	Breakers

Using this Manual

Due to the similarities of user interface and function of both the SmartBar and SmartModule, this manual references both products where common features exist.

In order to be specific about where features and commands are found, the following naming and text conventions will be used throughout this manual:

- Buttons and screen display items are indicated in **bold text**. For example: Press **INFO**. Choose **CHANNEL INFO** menu.

References to other parts of the quick guide are indicated in *italics*. When viewing this quick guide electronically, click on the reference to jump to that section in the document.

Throughout this manual, the following are used to alert you to notes and safety notices.



Note: *Notes are helpful hints and information that is supplemental to the main text.*



CAUTION: *Caution statement indicates situations where there may be undefined or unwanted consequences of an action, potential for data loss or an equipment problem.*



WARNING: *A Warning statement indicates situations where damage may occur, people may be harmed, or there are serious or dangerous consequences of an action.*

Please email comments about this manual to: TechComm@etconnect.com

Help from ETC Technical Services

If you are having difficulties, your most convenient resources are provided in this user manual. To search more widely, try the ETC website at www.etconnect.com. If none of these resources are sufficient, contact ETC Technical Services directly at one of the offices identified below.

Americas

Electronic Theatre Controls Inc.
Technical Services Department
3031 Pleasant View Road
Middleton, WI 53562
800-775-4382 (USA, toll-free)
+1-608 831-4116
service@etconnect.com

United Kingdom

Electronic Theatre Controls Ltd.
Technical Services Department
26-28 Victoria Industrial Estate
Victoria Road,
London W3 6UU England
+44 (0)20 8896 1000
service@etceurope.com

Asia

Electronic Theatre Controls Asia, Ltd.
Technical Services Department
Room 1801, 18/F
Tower 1 Phase 1, Enterprise Square
9 Sheung Yuet Road
Kowloon Bay, Kowloon, Hong Kong
+852 2799 1220
service@etcasia.com

Germany

Electronic Theatre Controls GmbH
Technical Services Department
Ohmstrasse 3
83607 Holzkirchen, Germany
+49 (80 24) 47 00-0
techserv-hoki@etconnect.com

Section 1: Unpacking & Setup

Unpacking & Checking

SmartBar/SmartModule dimmer units are self-contained dimming systems and only require a suitable main power input. See ["Power Input Connections"](#) below.

The SmartBar/SmartModule are packaged to withstand normal transportation, but before operating the unit, check that there is no sign of transit damage which could affect the operation and safety of the dimmer.

Positioning

The SmartBar/SmartModule are extremely versatile dimmers and can be incorporated in catwalks, near the lights, or used as a portable dimmer. They are designed for natural ventilation cooling. They cannot be flush mounted and must have a minimum of 1 inch clearance all the way around for air circulation. For added convenience the SmartBar is supplied with mounting hardware suitable for hanging fixtures.

Connections



Note: *All electrical connections to the SmartBar/SmartModule must be made by a suitably-qualified person.*

Power Input Connections

Input power is supplied via single or 3-phase supply depending on the dimmer model purchased. Reference ["Introduction" on page 1](#) for a listing.

The 6x10A SmartModule is supplied with a flange mounted GTL receptacle. The 4x6A SmartModule is supplied with a 12' bare end flexible cable and requires a suitable input connector, not supplied by ETC.

The SmartBar is supplied with a 12' bare end flexible cable and requires a suitable input connector, not supplied by ETC. The input connector should meet the following specifications depending on the model of dimmer supplied. Reference ["Introduction" on page 1](#) for detailed requirements of the unit purchased.

Input Supply type	Amp	Connector type
Single Phase	15A	5-15P Edison
Single Phase	20A	5-20P Edison
Single Phase	20A	L5-20P GTL
Three Phase	20A	L2120P GTL

Power Output Connections

The SmartBar includes a choice of one Stage Pin, Edison or GTL connector per channel. The SmartModule includes either Stage Pin or Edison connectors per channel. Connections to the loads are made by fitting the appropriate plug to the load cable.



Note: *Each 6A output is protected by a fuse which is 5x20mm ceramic fast blow 6.3A @ 250V. For replacements please contact ETC Technical Services and request ETC part number F245.*

Convenience Outlet (SmartBars Only)

A single auxiliary outlet is located centrally on the bar.

DMX Data Signal Connections

The dimmers are controlled using DMX 512. This is connected by a twisted and shielded data cable with XLR 5-pin connectors (male = input; female = output).

Use the male DMX connector on the SmartBar/SmartModule to input DMX data (such as from a console) and optionally use the female DMX connector to connect to other DMX devices in a daisy-chain manner.

Pin connections are:

- 1 Shield
- 2 DMX -
- 3 DMX +
- 4 Not used
- 5 Not used


The DMX network supports up to 32 SmartBar/SmartModules (192 dimmers in total) connected to each DMX line. For larger installations where more DMX lines are required, the use of a DMX splitter is recommended. Termination is required on all networks. The last DMX output socket in the line has to be terminated with two 120Ω 1/4 Watt resistors connected between pins 2 and 3 (DMX). A 'dummy plug' XLR male connector with the termination resistors fitted is recommended for this purpose.

Safety



WARNING: *Do not use the dimmer if the main power input cable has been damaged or the body of the case is not intact.*

Section 2: Control Panel Layout



ON LED: Illuminates blue when power is applied.

DMX LED: Illuminates red continuously when valid DMX is present. LED flashes when there is no DMX signal.

ENT & cursor arrows: ENT (Enter) completes a programming step and records the information in the memory. The four cursor arrows provide navigation through the set-up menu, and the means to enter data.

- ↑: Up cursor. Higher level menu feature or move cursor up in display screen or number increment.
- ↓: Down cursor. Lower level menu feature or move cursor down in display screen or number decrement.
- ←: Left cursor. Move cursor left in display screen.
- : Right cursor. Move cursor right in display screen.

DMX : Selects DMX address per channel when the single mode is selected, or the first address of the group when the joined mode is selected.

INST : Install function. To set up dimmer functionality during installation with options as follows:

- DMX configuration (single or joined)
- Channel configuration (single or joined)
- Channel information
- Password setup
- Dimmer hardware configuration
- Minimum level reset (preheat off when DMX is not present)
- Factory reset
- Sleep mode
- DMX backup levels
- DMX failure options

CHAS (with LED): Chase provides set-up for the dimmer's internal chase system for stand-alone display effects. The LED illuminates when the dimmer is in the 'chase mode.

CONF: Configure. Access to a sub-menu to set the detailed configuration for single or joined dimmer channels. Options available are:

- MAX:** Maximum. Sets the maximum output level from 30% to 100%, singly or joined.
- MIN:** Minimum. Sets the minimum output level from 0% to 29.9%, singly or joined.
- T-IN:** Response time to fade in from 0.00 secs to 99.99 secs.
- T-OUT:** Response time to fade out from 0.00 secs to 99.99 secs.
- CURVE:** Dimmer law selection
- I/O:** Non-dim on/off operation
- MODE:** Start mode (initiated after 5 minutes off) normal, soft start, burst, proportional.

MAN: Manual. Provides manual control of each channel for circuit testing and pre-setting.

EXIT: Returns to the opening screen menu option without recording changes.

INFO: Information. Provides a display of the nominal supply voltage and installed software version.

CHK (with LED): Check. Displays a log of any circuit or dimmer faults. LED illuminates if an error occurs.

PWR: Power. This function is not available in this product line.

Section 3: Function Overview

Maximum and Minimum Levels

The maximum output of the dimmer may be adjusted to improve lamp life or to limit the power used. A minimum level (preheat) may be necessary with some filaments to improve the speed of fast flashes or chases. A 'Minimum level reset' option exists (INST>General settings menu) to switch off the preheat when the DMX signal is not present (that is when the control desk is switched off).

Response Speed

Response speed is the time taken for a dimmer to 'fade' to the applied control signal level. It is used to control the rate of change of current to the filament and improve lamp life for higher wattage filaments.

Non-dim Operation

Each dimmer may be selected to operate as a dimmer, or as a non-dim switch. The programmed time of T-IN becomes the minimum on-time, T-OUT now has the function of minimum off-time.

Local Control

SmartBar/SmartModule have a range of integrated control facilities for basic operation without a control desk. These include live manual control of each dimmer level, preset recorded levels for fixed display lighting, and an integral chaser with 20 preset chase patterns and variable speed and level.

Dimmer Curves

A selection of dimmer curves (the relationship between control signal level and dimmer output) are available to compensate for the different visual responses of a live audience or a TV camera, and to provide improved dimming for non-resistive loads such as fluorescent tubes.

Backup Settings

Should the DMX signal fail, the SmartBar/SmartModule can be programmed to hold the present level, fade to zero or fade to a pre-programmed backup level.

Section 4: Information Displays & Manual Control

The following group of buttons provides direct access to detailed set-up and status information and manual override controls.

Check Dimmer Information

- Step 1: Press **INST**.
Step 2: Use **↑** or **↓** to choose **CHANNEL INFO** menu.
Step 3: Press **ENT**.
The screen displays:

```
INFO          CH: [ 1 ]
TEMP.        84 ' F 29 ' C
```

- Step 4: Press **←** or **→** to select other information as follows:

TEMPERATURE: Internal temperature.

DMX: DMX level received.

ACTUAL: The level the dimmer is responding to (may differ from DMX value due to MIN, MAX or MAN influence).

STATUS: Error message(s) with details.

- Step 5: Use **↑** or **↓** to select another dimmer channel (shown in square brackets), or,
Step 6: Press **EXIT** to leave the screen.

Check Set Dimmer Main Power Voltage & Frequency

- Step 1: Press **INFO**.
The screen displays:

```
LINE SETTING
U:120V   f: 60Hz
```

After 3 seconds, the screen automatically changes to show the next Info screen (Version).

Check Dimmer Software Version

- Step 1: Press **INFO** twice.
The screen displays:


```
Version 01.67
ETC (C) 2005
```

After 3 seconds, the screen automatically resets to show the normal output details.

Manually Control a Dimmer Level

You can control any dimmer directly from the front panel using the cursor controls to set the desired level. This can be used for testing circuits, overriding control signals or setting an independent fixed level. The level is mixed with any other incoming signal on a highest level takes precedence (HTP) basis.

Step 1: Press **MAN**, and its associated red LED lights.
The screen displays:



Step 2: Use **←** or **→** to select a channel number (active channel number is flashing), or **'T'** which controls all channels together.


Step 3: Use **↑** or **↓** to adjust the level. The dimmer output is live while the level is being adjusted.

Step 4: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

Operate the Chaser

The SmartBar/SmartModule have a sequence chaser to provide basic effects without a control desk. This can be used for exhibition and display lighting purposes.

Step 1: Press **CHAS**, and its associated red LED lights.
The screen displays:



where:

- **CH** is chase number.
- **T** is time (in seconds) from one step to another.
- **L** is a single bar showing the master intensity.
- **FAD** selects either a fading chase (ON) and a switching chase (OFF).

Step 2: Use **←** or **→** to move the brackets around the screen, and use **↑** or **↓** to adjust the selected parameter.

Step 3: With the chase number bracketed, use **↑** or **↓** to choose the desired chase pattern.

Step 4: Move the brackets to **T** to adjust the chase rate as desired.

Step 5: Move the brackets to **L** to set a new master intensity level as desired.

Step 6: Move the brackets to **FAD** to make the chase fade [ON] or switching effect [OFF].

Step 7: Press **ENT** to start the chase.

Step 8: Press **ENT** a second time to stop the chase (ENT toggles the chase on & off).

Step 9: Press **EXIT** to leave the chase functions.

Section 5: Programming

Flow Diagram

An overview of the flow chart showing the menu structure and options is shown in [“Menu Layout”, page 29](#).


General Programming Advice

Passwords

For clarity, the following sections which describe programming activities do not refer to the password entry. Passwords are included to prevent unauthorized access to the DMX, CONFigure, and INSTall menu trees. The passwords are four digit numbers with a factory default of 0000 (no password necessary). It is possible to have the same password for all or separate passwords for each menu tree. If any of the protected menus is selected, the subsequent screen requests a password. This is achieved by pressing the relevant ← or → cursor buttons to select the digit, and the ↑ or ↓ cursor buttons to enter the number.

Navigation Through the Menus

The cursor buttons are used to move around the menu screens, and to activate a set-up option or parameter prior to adjustment. When a parameter or option is activated, it is shown in square brackets, (such as [15]) and it is this item which you are changing on the screen. When you press **ENT** to confirm the change, the screen will show:



DATA IS STORED
IN MEMORY

As this happens for each menu option, it is not included in the following instructions.


Channel Characteristics

All dimmer-specific functional parameters may be set on a dimmer-per-dimmer basis. Thus each dimmer may have a different response time, curve, maximum level, etc. if required. Alternatively, all dimmers in one SmartBar/SmartModule can be programmed together, depending on whether the dimmer set-up has been set to 'SINGLE' or 'JOINED' (See [“Change the Dimmer Characteristic Setup Scheme” on page 12](#)). If the configuration is set to single, a number is shown in each relevant channel reference [4], and if all dimmers are programmed together, a **T** is shown in square brackets [T].

Front Panel Controls

All of the performance and control characteristics, measurements and status reports are available from the front panel controls and LCD. When power is applied, the power LED will illuminate. The DMX LED will illuminate if a valid DMX signal is present. If a valid DMX signal is not present, it will flash.

During the power-up reset process, the LCD shows identification details and the software version before displaying the output screen:



This display shows the channel levels (bargraphs at the top left), the DMX address of the first channel in the SmartBar/SmartModule (D:xxx). The number of bargraphs shown relates to the number of dimmers in the SmartBar/SmartModule – either 2, 4, or 6.




Note: An "X" behind the DMX address indicates that there is no valid DMX signal. SmartBar and SmartModule do not support DimStat in the United States.

General Controls

SmartBar/SmartModule have the capacity to store performance characteristics singly for each dimmer or joined for all dimmers in the group. This feature is independent of the choice of DMX numbering scheme, thus the dimmers may have single characteristics, but with consecutive DMX addresses.

Change the Dimmer Characteristic Setup Scheme

- Step 1: Press **INST**.
- Step 2: Use **↑** or **↓** to choose **GENERAL SETTINGS** menu.
- Step 3: Press **ENT**.
- Step 4: Use **↑** or **↓** to choose **CONFIG CHANNEL** menu.
- Step 5: Press **ENT**.
The screen displays:



- Step 6: Use **↑** or **↓** to select either **SINGLE** (for different individual channel parameters) or **JOINED** (if all dimmers have the same characteristics).
- Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

DMX Programming

Each dimmer is assigned a DMX channel number. A feature is provided to set sequential number groups ('joined' addressing) instead of individual settings ('single' addressing).

Set the DMX Addressing Scheme

- Step 1: Press **INST**.
- Step 2: Use **↑** or **↓** to choose **GENERAL SETTINGS** menu.
- Step 3: Press **ENT**.
- Step 4: Use **↑** or **↓** to choose **DMX ADDRESS** menu.
- Step 5: Press **ENT**.
The screen displays:

```
GENERAL
DMX MODE [START]
```

- Step 6: Use **↑** or **↓** to select either **SINGLE** (for different individual DMX addresses) or **START** (if the dimmers are numbered sequentially from the start address).
- Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

Set the DMX Addresses

- Step 1: Set the DMX scheme as described above (either single or start addressing).
- Step 2: Press **DMX**.
The screen displays:

```
DMX: [001]
CHAN: 1
```

- Step 3: To configure the DMX address(es), do one of the following.
- If **SINGLE** has been selected, two channels are displayed at a time, with their relevant DMX address. Use **↑** or **↓** to select the address needed for the first dimmer channel and move to other channels by pressing **←** or **→** and continue adjusting each DMX address by pressing **↑** or **↓** as before.
 - If **START** has been selected, only one DMX number is displayed (the first dimmer in this bar). Use **↑** or **↓** to select the address needed for the first dimmer channel. The remaining dimmers are automatically addressed in sequential order.
- Step 4: Press **ENT** to store the settings and to return to the previous menu.



Note:

DMX address 000 deselects the channel from operation. Valid DMX numbers are between 001 - 512. If higher dimmer numbers are used by the control desk, the number has to be rationalized to a base of 512 for the dimmer address (such as channel 600 is: 600 - 512 = DMX address 88).

Set the DMX Backup Condition

The SmartBar/SmartModule are equipped with a choice of responses to the loss of a DMX signal. The dimmers can be set to hold their last DMX level, fade to zero after 10 seconds, or fade to a preset memory setting.

- Step 1: Press **INST**.
- Step 2: Use **↑** or **↓** to choose **GENERAL SETTINGS** menu.
- Step 3: Press **ENT**.
- Step 4: Use **↑** or **↓** to choose **DMX FAIL** menu.
- Step 5: Press **ENT**.
The screen displays:

```
GENERAL
DMX FAIL [RESET]
```

- Step 6: Use **↑** or **↓** to select one of the 3 options available:
 - RESET:** sets all dimmers to zero after 10 seconds.
 - HOLD:** maintains the last valid DMX levels until DMX is restored.
 - BACKUP:** selects dimmer levels set-up through the backup memory facility.
- Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).



Note: *If BACKUP has been set, do not forget to pre-set the relevant DMX backup state.*

Set the DMX Backup Preset

- Step 1: Press **INST**.
 - Step 2: Use **↑** or **↓** to choose DMX BACKUP menu.
 - Step 3: Press **ENT**.
The screen displays:
- ```
BACK%: [000] 000
CHAN. : 1 2
```
- Step 4: Use **←** or **→** to select a channel number level (active channel level is in brackets).
  - Step 5: Use **↑** or **↓** to adjust the backup level. The dimmer output is live while the backup levels are adjusted.
  - Step 6: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Set the DMX Minimum Reset

DMX minimum reset is the automatic means to switch any preheat levels off when DMX is not present (that is when the control desk is switched off, but the dimmers remain on).

Step 1: Press **INST**.


Step 2: Use **↑** or **↓** to choose **GENERAL SETTINGS** menu.

Step 3: Press **ENT**.

Step 4: Use **↑** or **↓** choose **MINIMUM RESET** menu.

Step 5: Press **ENT**.

The screen displays:



A rectangular display area with a light green background. The text is black and centered. The top line reads 'GENERAL' and the bottom line reads 'MIN.RESET [OFF]'.

Step 6: Use **↑** or **↓** to select either **ON** (preheat switches off when DMX is off) or **OFF** (preheat runs continuously).

Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Maximum & Minimum levels

---

You can affect the output level of a dimmer by setting a minimum level and/or a maximum level. A minimum level is used to provide a level to preheat lamp filaments, whereas the maximum level is used to limit power and extend lamp life. Minimum levels may be set between 0 to 29.9%, and maximum levels from 30 to 100%. Factory default levels are 0 for minimum and 100% for maximum.



**Note:** *In the case of high-inrush loads (such as PAR cans) where flashing on from a cold state is required, a preheat level of 5% is recommended. See also “Set the DMX Minimum Reset”, page 15.*

---

### Set Max. & Min. Levels

Step 1: Press **CONF**.  
The screen shows the individual channel number (or **T** if the dimmer set-up scheme copies characteristics to all dimmers in the rack) and gives access to all configuration options.

Step 2: Use **←** to move the brackets to the channel number.  
The screen displays:

```
CONFIG: CH: [1]
MAX 100.0%
```

Step 3: Use **↑** or **↓** to select the required dimmer number.

Step 4: Use **→** to move the brackets to the parameter list.

Step 5: Use **→** to select the **MAX** or **MIN** option and to highlight the recorded value (in brackets).

The screen displays:

```
CONFIG: CH: 1
MIN [000.0]%
```

Setting options are:

**MIN:** Minimum level from 00 to 29.9%.

**MAX:** Maximum level from 30 to 100%.

Step 6: Use **↑** or **↓** to select the level (shown in brackets).

Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Response time

---

Each dimmer has two times associated with it which control the minimum time to fade in and out, and are called T-IN and T-OUT. These times are referred to as 'response times' and are used to protect the lamp filaments from thermal damage, and for reducing surges in the system. The default times are currently set at 0.02 seconds.

Values recommended are 0.01s for a 1kW load or 0.1s for a 2kW load.

### Set Dimmer Response Times

Step 1: Press **CONF**.  
The screen shows the individual channel number (or **T** if the dimmer set-up

scheme copies characteristics to all dimmers in the rack) and gives access to all configuration options.

- Step 2: Use ← or → to move the brackets to the channel number.  
The screen displays:

```
CONFIG: CH: [1]
MAX 100.0 %
```

- Step 3: Use ↑ or ↓ to select the required dimmer number.  
Step 4: Use → to move the brackets to the parameter list.  
Step 5: Use → to select the response times **T-IN** or **T-OUT** and to highlight the recorded value (in brackets).  
The screen displays:

```
CONFIG: CH: 1
T.OUT [00.02] s
```

- Step 6: Use ↑ or ↓ to select the time (shown in brackets).  
Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Dimmer Curves

---

Dimmer curves are used to adjust the relationship between control level and light output. This enables the dimmer to be fine-tuned to accommodate the preferences of a live audience or a television camera. There are ten factory standard dimmer curves, and a provision for further custom selectable curves in later software releases. The factory default curve (0) is Mod Square. The list of dimmer curves is as follows:

|                     |                                                                                   |
|---------------------|-----------------------------------------------------------------------------------|
| <b>LINEAR:</b>      | Linear relationship                                                               |
| <b>BBC:</b>         | BBC specification (modified square law for TV applications)                       |
| <b>S-LAW:</b>       | S-Law (Use this curve to match SmartBars with software previous to version 1.67.) |
| <b>INV.LIN:</b>     | Inverted (when control = zero, dimmer = full etc.)                                |
| <b>TVE:</b>         | Creates a BBC curve with a fluorescent ballast (switch to 40% at 5% control).     |
| <b>FLU-30:</b>      | Fluorescent (minimum 30%)                                                         |
| <b>MOD SQUARE:</b>  | Modified square law (default) Built to match Smartpack and Sensor+                |
| <b>FLASH:</b>       | Flash effect (light switches on and off as the control fades up and down).        |
| <b>NON DIM:</b>     | Non-dim operation (see note below)                                                |
| <b>2kWL:</b>        | Linear curve with a S-law first 15%                                               |
| <b>Usr1 - Usr6:</b> | For user definable custom curves                                                  |



---

**Note:** *110V LIN has been removed starting in version 1.67. MOD SQUARE curve has replaced 110V LIN and is now the default curve.*

---



**Note:**

There are two options for setting Non-Dim (switch) operation - via the CURVE menu and the NON-DIM menu, both found in CONF. For Non-Dim operation, either or both options may be set, but for normal dimmer operation BOTH must be set to 'NO'.

### Set a Dimmer Curve

Step 1: Press **CONF**.  
The screen shows the individual channel number (or **T** if the dimmer set-up scheme copies characteristics to all dimmers in the rack) and gives access to all configuration options.

Step 2: Use **←** to move the brackets to the channel number.  
The screen displays:

```
CONFIG: CH: [1]
MAX 100.0 %
```

Step 3: Use **↑** or **↓** to select the required dimmer number.

Step 4: Use **→** to move the brackets to the parameter list.

Step 5: Use **→** to select the **CURVE** setting and to highlight the recorded value (in brackets).

The screen displays:

```
CONFIG: CH: 1
CURVE [MOD SQUARE]
```

Step 6: Use **↑** or **↓** to select the curve option (shown in brackets).

Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

### Start Mode

The SmartBar/SmartModule are equipped with a software feature to alter the criteria for dimming cold filaments. The response of a dimmer depends on the resistance of the filament, which varies according to temperature. A cold filament has a slower response than a warm filament. If the complete rig is subject to a sudden loss and resumption of power (a 'brown-out') it is possible for the combined cold switch-on load to be higher than the diversified power supply can withstand, resulting in nuisance tripping of circuit breakers. For this reason, the dimmers are installed with a range of start modes to give the users flexibility in the set-up characteristics of the dimmer.

**BASIC:** Normal mode

**SOFT:** If the circuit has not been used for 5 minutes, the initial response time is automatically set to 500mS

## Set Start Mode

Step 1: Press **CONF**.

The screen shows the individual channel number (or **T** if the dimmer set-up scheme copies characteristics to all dimmers in the rack) and gives access to all configuration options.

Step 2: Use **←** to move the brackets to the channel number.  
The screen displays:

```
CONFIG: CH: [1]
MAX 100.0 %
```

Step 3: Use **↑** or **↓** to select the required dimmer number.

Step 4: Use **→** to move the brackets to the parameter list.

Step 5: Use **→** to select the start **MODE** option and to highlight the recorded value (in brackets).

The screen displays:

```
CONFIG: CH: 1
MODE [BASIC]
```

Step 6: Use **↑** or **↓** to select the start **MODE** option (shown in brackets).

Step 7: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Passwords

---

Passwords are used at three levels of the set-up procedure: DMX, CONF. and INST. One password or three separate passwords may be used to give a range of access options. Passwords are in the form of four digit codes and may be set and used from the front panel of the dimmer. Passwords set at 0000 give unlimited access (factory default).



**Note:** *If the password is set to 0000 (factory default) the menus are open, and no prompts to enter a password are seen on the display.*

---

## Setup Passwords

---



**Note:** *Programming passwords for DMX programming, Channel configuration and Installation follows the same procedure which is described here for DMX only.*

---

Step 1: Press **INST**.


Step 2: Press **↑** or **↓** to choose **PASSWORD DMX** menu.

Step 3: Press **ENT**.

The screen displays:

```
NEW PASSWORD
* : * : * : *
```

- Step 4: Use **↑** or **↓** to adjust the digit.  
The screen displays:



NEW PASSWORD  
[ 1 ] : \* : \* : \*

- Step 5: Use **←** or **→** to select a digit to enter (shown in brackets).



**Note:**

*Make a copy of passwords set in the back of this manual.*

*Resetting the password to 0000 disables the previous setting.*


- Step 6: Press **ENT** (to record the changes) or **EXIT** (to leave the previous settings unchanged, and return to the home page).

## Sleep mode

The SLEEP function has been included to switch off the backlit LCD during a performance when the control panels are in view of an audience or camera. When enabled, the sleep function switches off the backlight a short time after the last touch of a panel button, and switches back on when a front panel button is pressed.

### Set the dimmer rack to Sleep mode

- Step 1: Press **INST**.
- Step 2: Use **↑** or **↓** to choose **GENERAL SETTINGS** menu.
- Step 3: Press **ENT**.
- Step 4: Use **↑** or **↓** to choose **SLEEP MODE** menu.
- Step 5: Press **ENT**.  
The screen displays:



GENERAL  
SLEEP MODE [ OFF ]


- Step 6: Use **↑** or **↓** to select either ON or OFF.
- Step 7: Press **ENT** to leave the menu and record the changes or **EXIT** (to leave the previous settings unchanged).



## Fault reporting

---

The SmartBar/SmartModule will report if a dimmer is overheating or if there is an over voltage. The CHK LED illuminates if a fault is recorded and any circuit errors are reported on the screen above the channel number affected. Example as shown below for channel 4 which is displaying a temperature overheat condition:



L.:■■■t■■■ D:001✓  
CH 123456 A:000x

where:

code 'l' = no load, such as lamp or fuse failure, or a disconnected load

code 't' = over temperature (>78 °C/172 °F)

code 'u' = over voltage present (>145V AC)

The channel display indicators give the last recorded fault condition. A summary of the history is shown using the dimmer's LCD in the next topic below.


### Check Error Messages & Reset the Log

Step 1: Press **CHK**.




**Note:** *This screen never requires a password.*

If there is no error, the screen shows the following message for 3 seconds:



STATUS: OK

If there is an error, the screen displays:



STATUS: CH  
OVERTEMP 04

Error type ————— Channel number of the error

Step 2: Use **↑** or **↓** to view any other messages in the error log.

Step 3: Press **ENT** to leave the menu and **clear** the log or **EXIT** (to leave the log unchanged).

## Restore Factory Defaults

---

The SmartBar/SmartModule are supplied with a set of factory default settings and recommended software set-up parameters. It is advisable to reset the dimmer software to the original factory settings in the case of a significant software update.


### Reset to Factory Default Settings

Step 1: Press **INST**.

Step 2: Use **↑** or **↓** to choose **FACTORY RESET** menu.

Step 3: Press **ENT**.

- The screen displays:



ARE YOU SURE ??  
CLEAR MEM. [ NO ]

Step 4: Use **↑** or **↓** to select **YES**.

Step 5: Press **ENT** to leave the menu and reset the dimmer's memory or **EXIT** (to leave the previous settings unchanged).

**Factory defaults are:**

**CHANNEL CONFIG:** JOINED

**CURVE:** MOD SQUARE

**DMX ADDRESS:** 001

**DMX BACKUP:** all 00

**DMX FAIL:** RESET

**DMX MODE:** JOINED

**DMX MINIMUM RESET:** OFF

**FREQUENCY:** 60Hz

**MAXIMUM:** 100%

**MINIMUM:** 0.00%

**MODE:** BASIC

**NON-DIM (I/O):** NO

**PASSWORDS:** all 0000

**PC ADDRESS:** 000

**SLEEP:** OFF

**T-IN:** 0.02 secs.

**T-OUT:** 0.02 secs.

# Section 6: Faults & Troubleshooting

---

## Reported Faults

---

### Over Temperature

If one of the dimmer channels exceeds an operating temperature of 78 °C (172 °F), the dimmer will switch off and report an over temperature condition. This can be caused if the ventilation is obstructed (such as the dimmer is resting on the floor and is being used continuously at full load).

### Over Voltage

If one or more of the dimmer channels exceeds an operating voltage of greater than 145V AC, the dimmer will switch off and report an over voltage condition.

### No Load (Control Present But no Output) [SmartModule Only]

This can be reported if either a load fails (lamp blows or fuse has failed), or the load is disconnected in error, or a load is not connected.

## First Line Troubleshooting

---

This check list provides initial assistance in the case of a problem which has not been identified and reported by the dimmer's own software.

### LCD Display Blank

Check all power supply connections.

### No Output from One Channel

Check the channel breaker or fuse. Check the control signal is active. Check the DMX address is correct.

### Breaker Trips Continuously

Unplug all load plugs. Check the circuit (cables, plugs and sockets, distribution, and lights) for loose terminals, a phase to neutral short, a phase to earth short, or a neutral to earth short. Ensure that the load does not exceed the circuit breaker capacity. Correct where necessary. If the fault persists, please contact your ETC equipment supplier or ETC Technical Services.

### Dimmer Output is Stuck On Full

Disconnect the DMX cable to isolate control. If the dimmer is still on, check a) the MANUAL level has not been set to 100%; b) the dimmer curve has not been set to 'Inverted'; c) the MIN level is at zero. If the dimmer is still on, please contact your ETC equipment supplier or ETC Technical Services.

If the dimmer switches off when the DMX cable is removed, check that both NON-DIM mode selections (dimmer curve and Channel Configuration I/O) are set to OFF. If either or both these functions are set ON, the dimmer will be operating in Non-Dim mode.



# Appendix A: Specifications

---

## SmartBar/SmartModule Control Features



---

- DMX512 in and thru via 5 pin XLR connectors
- Supports up to 32 SmartBar/SmartModule on one DMX line (Opto-splitter recommended for additional units)
- Two-line by 20-character backlit LCD for system configuration, status display and error indication
- Nine-button keypad plus arrow array and Enter button
- Two status LED indicators: Power and Valid DMX
- Flexible programming of individual dimmer characteristics:
  - Maximum and minimum levels
  - Response speed
  - Local control or live manual control
  - 20 pre-programmed effect sequences
  - Selection of standard dimmer curves
  - Non-dim operation
  - Start Mode for dimming cold filaments – basic or soft
  - Status reporting
  - Backup settings - Selectable Data Loss Behavior
- Password protection for access to DMX, Configuration and Install menus

## SmartBar Specifications

---

### General

- 2, 4, or 6 dimmer versions available
  - 4x6A
  - 2x10A and 6x10A
- UL Listed and cUL approved.  
- Installation requires attachment of safety cables
- Main power via flexible 12' (3.65m) cable
- Data via DMX512

## Physical

| Model  | Height |    | Width  |    | Length |      | Weight |      |
|--------|--------|----|--------|----|--------|------|--------|------|
|        | inches | mm | inches | mm | inches | mm   | lbs    | kg   |
| SB4-6  | 2.36   | 60 | 2.6    | 40 | 59.5   | 1500 | 11     | 5    |
| SB2-10 | 2.36   | 60 | 3.1    | 80 | 42.5   | 1000 | 15     | 6.8  |
| SB6-10 | 2.36   | 60 | 3.1    | 80 | 87.4   | 2200 | 27.8   | 12.6 |

## Mechanical

- Manufactured of aircraft quality anodized aluminium
- Integrated suspension points for fixtures and for mounting hardware (such as hook clamps or stand adaptors)
  - Supplied with 3 1/4" long 1/2" bolts and appropriate hardware for fixture mounting
- Convection cooled – operates without cooling fans or filters



## Electrical

- 120/208V 60Hz main power supply
- **4x6A and 2x10A:** 120V single-phase 2-wire + ground, 20A feed
- **6x10A:** 120/208V three-phase 4-wire + ground, 20A feed
- Total load can not exceed capacity of main power connection (wall outlet, 15A, 20A)
- Input power via an attached flexible 12' SO feed cord and bare-ends (connector not supplied)
- 10W Minimum load per dimmer
- Edison, stage pin or Twist-Lok outlets (1 per circuit)
- 6A units: fuse for load protection per dimmer
- 10A units: circuit breaker for load protection
- Quality rise time filtering measured at 120µs (6A) and 320µs (10A)

# SmartModule Specifications

---

## General

- Four 6A dimmers
- Six 10A dimmers
- UL Listed and cUL approved  
- Installation requires attachment of safety cables
- Main power via 12' (3.65m) cable with bare ends or via 20A GTL input connector
- Data via DMX512

## Physical

| Model  | Height |     | Width  |     | Length |     | Weight |     |
|--------|--------|-----|--------|-----|--------|-----|--------|-----|
|        | inches | mm  | inches | mm  | inches | mm  | lbs    | kg  |
| SM4-6  | 6.36   | 162 | 3.03   | 77  | 13.75  | 349 | 10     | 4.5 |
| SM6-10 | 8.66   | 220 | 4.9    | 125 | 17.76  | 451 | 20     | 9.1 |

## Mechanical

- Manufactured of aircraft quality anodized aluminium
- Integrated suspension points (threaded studs) for mounting hardware such as hook clamps
- Convection cooled – operates without cooling fans or filters


## Electrical


- 120/208V 60Hz main power supply
- **4x6A:**
  - 120V single-phase 2-wire + ground, 20A feed
  - Power wiring by use of an attached flexible 12' feed cord and bare ends. Connector is not supplied by ETC
  - Fuse per dimmer for load protection
  - Edison and stage pin outlets only
- **6x10A:**
  - 120/208V three-phase 4-wire + ground, 20A feed
  - Power feed via 20A three-phase flange mount GTL connector
  - Circuit breaker per dimmer for load protection
  - Edison, stage pin or Twist-Lok outlets





# Appendix B: Menu Layout









**Corporate Headquarters** ■ 3031 Pleasant View Road, P.O. Box 620979, Middleton, Wisconsin 53562-0979 USA ■ Tel +608 831 4116 ■ Fax +608 836 1736  
**London, UK** ■ Unit 26-28, Victoria Industrial Estate, Victoria Road, London W3 6UU, UK ■ Tel +44 (0)20 8896 1000 ■ Fax +44 (0)20 8896 2000  
**Rome, IT** ■ Via Ennio Quirino Visconti, 11, 00193 Rome, Italy ■ Tel +39 (06) 32 111 683 ■ Fax +39 (06) 32 656 990  
**Holzkirchen, DE** ■ Ohmstrasse 3, 83607 Holzkirchen, Germany ■ Tel +49 (80 24) 47 00-0 ■ Fax +49 (80 24) 47 00-3 00  
**Hong Kong** ■ Rm 1801, 18/F, Tower 1 Phase 1, Enterprise Square, 9 Sheung Yuet Road, Kowloon Bay, Kowloon, Hong Kong ■ Tel +852 2799 1220 ■ Fax +852 2799 9325  
**Service:** (Americas) [service@etconnect.com](mailto:service@etconnect.com) ■ (UK) [service@etceurope.com](mailto:service@etceurope.com) ■ (DE) [techserv-hoki@etconnect.com](mailto:techserv-hoki@etconnect.com) ■ (Asia) [service@etcasia.com](mailto:service@etcasia.com)  
**Web:** [www.etconnect.com](http://www.etconnect.com) ■ Copyright © 2009 ETC. All Rights Reserved. ■ Product information and specifications subject to change.  
**7521M1200-1.67** ■ Rev A ■ Released 2009-04